



**Plan Review Information**

- The technical review and comment is intended to evaluate the completeness of the Construction/Stormwater Pollution Prevention Plan for the project. All measures included in the plan, as well as those recommended in the comments, should be evaluated as to their feasibility by a qualified individual with structural measures designed by a qualified engineer. The Plan has not been reviewed for other local, state, or federal permits that may be required to proceed with this project.
- Additional information, including design calculations may be requested to further evaluate the plan.
- All proposed stormwater pollution prevention measures and those referenced in this review must meet the design criteria and standards set forth in the "Indiana Stormwater Quality Manual" from the Indiana Department of Environmental Management, the City of Hobart Stormwater Technical Standards Manual, or similar Guidance Documents.
- Construction activities and unforeseen weather conditions may affect the performance of the erosion and sediment control system, individual measures, or the effectiveness of the plan. The plan must be a flexible document, with provisions to modify or substitute measures as necessary to ensure compliance.

**Priority Site Information:**

<input type="checkbox"/>	<b>Nature and Extent of Construction</b>	<input type="checkbox"/>	<b>Existing Pollution Issues on Project Site</b>
<input type="checkbox"/>	<b>Close Proximity to Sensitive Area(s)</b>	<input type="checkbox"/>	<b>Potential for Direct Runoff to Receiving Waters</b>
<input type="checkbox"/>	<b>Steep Topography on Proposed Construction Site</b>	<input type="checkbox"/>	<b>Not a Priority Site</b>

**Section A: Construction Plan Elements**

<b>Adequate</b>	<b>Deficient</b>	<b>NA</b>	<b>A</b>	<i>The construction plan elements include general information associated with the project site that are critical for the evaluation of the stormwater pollution prevention plan component. This information includes, but is not limited to, an index, resource information, reference maps, grading information, project layout and design, and drainage plan</i>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>1</b>	Index of the location of required plan elements in the construction plan
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>2</b>	A vicinity map depicting the project site location in relationship to recognizable local landmarks, towns, and major roads
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>3</b>	Narrative of the nature and purpose of the project
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>4</b>	Latitude and longitude to the nearest fifteen (15) seconds
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>5</b>	Legal description of the project site including the legal section, township and range
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>6</b>	11 X 17-inch plat showing building lot numbers/boundaries and road layout/names
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>7</b>	Boundaries of the one hundred (100) year floodplains, floodway fringes, and floodways
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>8</b>	Land use of all adjacent properties
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>9</b>	Identification of a U.S. EPA approved or established TMDL
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>10</b>	Name(s) of the receiving water(s)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>11</b>	Identification of discharges to a water on the current 303d list of impaired waters and the pollutant(s) for which it is impaired
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>12</b>	Soil map of the predominant soil types including a description of soil properties, characteristics, limitations, and hazards associated with the project site
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>13</b>	Identification and location of all known wetlands, lakes and water courses on or adjacent to the project site (construction plan, existing site layout)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>14</b>	Identification of any other state or federal water quality permits or authorizations that are required for construction activities
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>15</b>	Identification and delineation of existing cover, including natural buffers (50-ft buffer required)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>16</b>	Existing topography at a contour interval appropriate to indicate drainage patterns
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>17</b>	Location(s) of where run-off enters the project site prior to land disturbance
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>18</b>	Location(s) of where run-off discharges from the project site prior to land disturbance. Erosion control measures required at the discharge point.

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>19</b>	Location of all existing structures on the project site
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>20</b>	Existing permanent retention or detention facilities, including manmade wetlands, designed for the purpose of stormwater management
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>21</b>	Locations where stormwater may be directly discharged into ground water, such as abandoned wells, sinkholes, or karst features
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>22</b>	Size of the project area expressed in acres
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>23</b>	Total expected land disturbance expressed in acres
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>24</b>	Proposed final topography, grading plan.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>25</b>	Locations and approximate boundaries of all disturbed areas
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>26</b>	Location, size, and dimensions of all stormwater drainage systems, such as culverts, storm sewers, and conveyance channels
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>27</b>	Locations of specific points where stormwater and non-stormwater discharges will leave the project site
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>28</b>	Location of all proposed site improvements, including roads, utilities, lot delineation and identification, proposed structures, and common areas
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>29</b>	Location of all on-site soil stockpiles and borrow areas. Topsoil must be preserved.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>30</b>	Construction support activities that are expected to be part of the project
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>31</b>	Location of any in-stream activities that are planned for the project including, but not limited to stream crossings and pump arounds
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>32</b>	Identification of any current or previous uses of the project site or immediately adjacent properties which may have resulted in the presence of hazardous substances, pollutants or contaminants on the project site.
<b>Section A – Comments:</b>				
•				

<b>Section B: Stormwater Pollution Prevention Plan – Erosion and Sediment Control/Project Site Management</b>				
<b>Adequate</b>	<b>Deficient</b>	<b>NA</b>	<b>B</b>	<i>The construction component of the Stormwater Pollution Prevention Plan includes stormwater quality measures to address erosion, sedimentation, and other pollutants associated with land disturbance and construction activities. Proper implementation of the Plan, maintenance of measures, and administering a self-monitoring program is required to manage the project site to minimize the discharge of sediment and other pollutants. Construction activities and unforeseen weather conditions may affect the performance of the erosion and sediment control system, individual measures, or the effectiveness of the Plan. The Plan must be a flexible document, with provisions to modify or substitute measures as necessary to ensure compliance.</i>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>1</b>	Description of the potential pollutant generating sources and pollutants, including all potential non-stormwater discharges
Where applicable, Items in 2 through 10 below will be evaluated for Location, dimensions, detailed specifications, and construction details				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>2</b>	Stable construction entrance locations and specifications. Plan to clear tracking of sediments on road. Dust suppression plan.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>3</b>	Specifications for temporary and permanent stabilization. Include seeding and mulching plan, 70% coverage requirement for final stabilization and 7-day stabilization requirement.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>4</b>	Sediment control measures for concentrated flow areas (sediment basins if used have specific requirements)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>5</b>	Sediment control measures for sheet flow areas
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>6</b>	Run-off control measures
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>7</b>	Stormwater outlet protection locations and specifications
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>8</b>	Grade stabilization structure locations and specifications
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>9</b>	Dewatering applications and management methods

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>10</b>	Measures utilized for work within waterbodies
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>11</b>	Maintenance guidelines for each proposed temporary stormwater quality measure. Monitoring and project management plan to include self-monitoring program (SMP), self-inspections and project management log
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>12</b>	Planned construction sequence describing the relationship between implementation of stormwater quality measures in relation to land disturbance
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>13</b>	Provisions for erosion and sediment control on individual building lots regulated under the proposed project
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>14</b>	Material handling and spill prevention and spill response plan meeting the requirements in 327 IAC 2-6.1
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>15</b>	Material handling and storage procedures associated with construction activity. Include management of waste materials and dumpsters for runoff and wind, concrete washout management, fueling areas, equipment washing, application of pesticides, herbicides, insecticides and fertilizers, disposal of hazardous waste and washing of paint or grout applicators.
<b>Section B – Comments:</b>				
•				

<b>Section C: Stormwater Pollution Prevention Plan – Post-Construction</b>				
Adequate	Deficient	NA	<b>C</b>	
<i>The post-construction component of the Stormwater Pollution Prevention Plan includes the implementation of stormwater quality and quantity measures to address pollutants that will be associated with the final project land use. Post-construction stormwater measures should be functional upon completion of the project. Long term functionality of the measures is critical to their performance and should be monitored and maintained.</i>				
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>1</b>	Description of pollutants and their sources associated with the proposed land use
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>2</b>	Description of proposed post-construction stormwater measures including stormwater quantity and water quality treatment according to the local ordinance and standards.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>2a</b>	Include a description of the treatment train and a depiction of the one-line flow path of all water quality measures included in the treatment train.
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<b>2b</b>	Water quantity (detention) calculations.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>2c</b>	Water quality calculations, include the water quality flow rate and/or water quality volume calculation.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>3</b>	Plan details for each post-construction stormwater measure
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>4</b>	Sequence describing stormwater measure implementation
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>5</b>	Maintenance guidelines for proposed post-construction stormwater measures. Provide an Operation and Maintenance (O&M) Manual.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>6</b>	Entity that will be responsible for operation and maintenance of the post-construction stormwater measures
<b>Section C – Comments:</b>				
•				